

ORDINANCE NO. 4-2

The Board of Trustees of the Charter Township of Hampton, Bay County, Michigan, ordains:

That Ordinance No. 4 of the Charter Township of Hampton, being the Charter Township of Hampton Water Ordinance, be amended as follows:

SECTION A

The Charter Township of Hampton Ordinance No. 4, designated as Charter Township of Hampton Water Ordinance, adopted June 13, 1969, is hereby amended in part to read as follows:

Section 6. Service pipes from water main to shut off and from shut off to meter must be copper unless such pipe is above 2 inches diameter, in which case cast iron or cement asbestos pipe may be used. Copper pipe shall be type "K" for use in underground water services. Cast iron pipe shall be Class 150 AWWA standard cast iron water pipe. Cement asbestos pipe shall conform to AWWA C-400-53T and SSP-351 a.

The minimum size service connection pipe allowable to be 3/4 inch diameter.

SECTION B

The penalty for violation of this ordinance shall be the same as those penalties set forth in Section 28 of the Charter Township of Hampton Ordinance No. 4.

SECTION C

A copy of this ordinance shall be published in a newspaper circulated within the Charter Township of Hampton, Bay County, Michigan, within ten (10) days following the adoption thereof.

SECTION D

These amendments to Ordinance No. 4 shall become effective thirty (30) days after the last required publication.

SECTION E

All ordinances or parts of ordinances in conflict herewith are hereby repealed.

SECTION F

Should any section, clause or provision of this ordinance be declared by the courts to be invalid, the same shall not affect the validity of this ordinance as a whole or any part thereof other than the part declared to be invalid.